

Product Type Approval Certificate

Full


This certificate is issued to:

Supplier name and address:	Raychem (TE Connectivity) Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
-----------------------------------	---

In respect of:

Manufacturer:	Raychem (TE Connectivity)
Place of manufacture:	Unit 2, No 3 Corella Close, Berkeley Vale NSW 2261
Product description:	Raychem ESD-5115-AU-05/19 – Joint for 33 kV screened single core XLPE insulated cables 240 mm ² - 400 mm ² , with or without DTS fibre optics
Use approved for:	Joint for 33 kV single core XLPE insulated cables 240 mm ² - 400 mm ² , complying with T HR EL 20001 ST
Conditions of approval:	Joint kit shall be installed by staff that are Accredited Cable Jointers in accordance with Sydney Trains document PR-D-78701 <i>Personnel Certifications – Electrical</i> , and trained by TE Connectivity in accordance with the requirements of EP 20 00 03 01 SP
Limitations:	NA

Evaluating rail transport operator

Name:	Terry Niemeier
Position:	Lead Electrical Engineer, Asset Standards Authority, Transport for NSW
Signature:	
Date:	22/05/2019

Product approval pack reference number: fA1169784