



Product Type Approval Certificate

Full

This certificate is issued to:

Supplier name and address:	Olex Australia Pty Limited Level 15/300 La Trobe Street, Melbourne Victoria 3000
-----------------------------------	---

In respect of:

Manufacturer:	Nexans (Yanggu) New Rihui Cable Co. Ltd
Place of manufacture:	No. 14, Xihu, Yanggu, Liaocheng City, Shandong, China
Product description:	Nexans Marketing Code: XNNP27RW001CXAA DESCRIPTION: 1 Conductor 300 mm ² Stranded Compacted Plain Annealed Copper, Semi conductive Conductor Screen (0.3 mm min wall), 19/33 kV TR-XLPE Insulated (8.0 mm nom wall), Strippolex Insulation Screen (0.6 mm min wall), Copper Wire Screened (40 x 1.70 mm nom diam, area 90 mm ² min suitable for 13.5 kA for 1 sec fault level), PVC (5V-90) Sheathed (2.0 mm min wall), HDPE Sheathed (2.0 mm min wall), to AS/NZS 1429.1 and TfNSW Standard T HR EL 20001 ST.
Use approved for:	Applications in accordance with T HR EL 20001 ST
Conditions of approval:	Approval applies to ASA evaluated material grades only – details held by ASA. Changes to insulation and sheath material grades for use in this cable item require resubmission to ASA for technical evaluation.
Limitations:	NA

Evaluating rail transport operator

Name:	Lidija Dumbaloska
Position:	Director Energy Networks and Systems
Signature:	<i>L. Dumbaloska</i>
Date:	24/09/21

Product approval pack reference number: FA745778